# OPERATING INSTRUCTIONS RC2106



# SPECIFICATIONS DISPLAY

Type:7 segment LED; Height: 0.5" Rate mode: 4 digits

#### **RANGE**

Rate: Auto ranging(4.00 to 9999RPM)

# ACCURACY

Rate: 0.05 % SCALE FACTOR

Programmable from 0.001 to 9.999  $\times 10^n$ n = 0, 1, 2, -3, -2, -1,

#### **INPUTS**

3-30 VDC From Proximity Switch, Encoder, Solid State Device, Mechanical Switch, Potential Free Contact.

#### **SENSOR SUPPLY**

12 VDC(±10%), 30 mA

#### CONFIGURATION LOCK

Via rear terminals

#### SUPPLY VOLTAGE

90 to 270 V AC/DC

24V AC/DC

#### **OPERATING TEMP.**

0-50°C

#### HUMIDITY

95% RH

## **HOUSING**

ABS plastic


#### **WEIGHT**

200 gms

#### PRODUCT CODE


| MODELS | BEZEL SIZE(mm) |
|--------|----------------|
| RC2106 | 72 x 72        |

# **OVERALL DIMENSIONS** (All dimensions in mm)




#### **TERMINAL CONNECTIONS**

#### Potential Free switch










#### **TERMINAL DESCRIPTION**

- 1 +12V
- 2 CNT
- Short for config
- L Live (+)
- N Neutral (-)

## Input connection for proximity sensor:-



Note: Color codes for proximity sensors-Brown / Red --> +12V Black / Green --> CNT Blue / Black --> GND

#### INITIALISATION:

#### **CONFIGURATION SCHEME**

(parameter setting)


- 1) Before configuration: Short terminal no 4 & 5
- 2) Turn power on
- 3) Program configuration setting as per instructions below
- 1. To select scale factor mantissa

| KEY PRESS             | DISPLAY | DESCRIPTION  |
|-----------------------|---------|--------------|
| Scale factor mantissa | 0.000   | as acsoribed |

The blinking digit increments by 1 for every press of the A key & rolls over from 9 to 0. The blinking

digit shifts to next digit (right) for every press of key. Using these keys user can set the required value.

# 2. Press RST key to select scale factor exponent



- 1) Turn power off
- 2) Remove link between terminal no 4 & 5
- 3) Turn power on



If terminal no 4 & 5 are shorted at power on, rate indicator will go in to the configuration mode. To quit configuration setting mode, turn power off, remove link between 4 & 5 & switch power on.

# TO READ SCALE FACTOR KEY PRESS (MOMENTARY) Press Scale Factor (Mantissa) Press Scale Factor (Exponent)

**NOTE:** Maximum display time is 3 sec. If the key is pressed again within 3 sec of previous key press display shows next parameter, otherwise it shows rate or total as per selection.

### **TYPICAL APPLICATION:**


<u>Objective</u>: To display the delivery rate of the cord (meters/minute).

Data available:

**Example 1**: The proximity switch generates one pulse per revolution of the measuring wheel.

The diameter of the measuring wheel is 10 cm.

Document name: Operating/1007/RC2106 ver2 OP-080-V02B Page 1 of 2



#### Example 2:

In above application if 60 PPR encoder is fitted instead of proximity.

Therefore a) The length of rope delivered per revolution is 0.3142857 meters b) The number of pulses per revolution = 60 c) Length of rope delivered per count pulse = 0.3142857 /60 = 0.005238 meter.

The display should increment by 0.005238 for every pulse. therefore, scale factor =  $5.23800 \times 10^{\circ}$ 

Set scale factor mantissa = 5.23800 & exponent =  $10^{-3}$  for required display.

#### Selec Controls Pvt. Ltd.

Specifications are subject to change, since development is a continuous process

Telephone: +91-22-40394200 / 40394202

Fax: +91-22-28471733
Toll free: 1800 227 353
Website: www.selec.com
Email: sales@selec.com
Operating/1010/RC2106/0P080-V02B

(Page 2 of 2)

#### **Calculations**

The circumference of the wheel =  $3.142857 \times 0.1$  = 0.3142857 meters.

Therefore the length of rope delivered per revolution is 0.3142857 meters.

Since the proximity switch gives one pulse per revolution , the display should increment by 0.3142857 for every pulse. Therefore, scale factor = 0.3142857

Set scale factor mantissa = 3.14285 & exponent =  $10^{-1}$ 

The RC2106 will show rate in meters/minute.